

*Official copies of these procedures are maintained at this website.
Before using a printed copy, verify that it is the most current
version by checking the document issue date on this website. Signed
copies of these official procedures are maintained at the Training Office.*

C-A OPERATIONS PROCEDURES MANUAL

ATTACHMENT

11.2.3.a PHENIX Flammable Gas Checklist

C-A-OPM procedure in which this attachment is used.		
11.2.3		

Hand Processed Changes

<u>HPC No.</u>	<u>Date</u>	<u>Page Nos.</u>	<u>Initials</u>
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

Approved: Signature on File _____
 Collider-Accelerator Department Chairman Date

M. Sivertz

11.2.3.a PHENIX Flammable Gas Checklist

The PHENIX Run Coordinator and Liaison Physicist must go over the following checklist and verify that all items on the list have been completed. When they are satisfied, they attach their signatures below.

Checklist Item	RC	LP
Mixing House Smoke Detection Blue Sheet		
Mixing House Flammable Gas Sensor Blue Sheet		
IR Flammable Gas Sensor Blue Sheet		
IR Smoke Detection Blue Sheet		
SMCS Blue Sheet		
Inspection of flammable gas piping		
Subsystems purged with inert gas		
PHENIX Shift People on shift		
High Voltage Off on all subsystems receiving flammable gas		

PHENIX Run Coordinator _____
Signature Date

PHENIX Liaison Physicist _____
Signature Date